



**Institute of Ceramics
and Building
Materials**

Division of Glass and Building Materials in Krakow

31-983 Krakow, Cementowa 8 Str.

tel.: +48 12 683 79 00

fax: +48 12 683 79 01

www.icimb.pl

info_krakow@icimb.pl

Department of Gypsum and Building Chemistry

tel.: +48 12 683 79 77

m.niziurska@icimb.pl



AB 054

Sponsor: River Power s.r.o., Hlubinská 1378/36, 702 00 Ostrava, Czech Republic

Sample: INSULATING PAINT PSC - 250T

TEST CERTIFICATE (16.02.2018 version 2.0)

| | |
|--|---|
| 1) Water - vapor permeability PN-EN ISO 7783:2011 | 6,2 g/m²d |
| 2) Water permeability PN-EN 1062:2008 | |
| 10 min | 0,01 m²·h^{0,5} |
| 30 min | 0,01 m²·h^{0,5} |
| 1 h | 0,00 m²·h^{0,5} |
| 2 h | 0,01 m²·h^{0,5} |
| 3 h | 0,01 m²·h^{0,5} |
| 6h | 0,00 m²·h^{0,5} |
| 24 h | 0,01 m²·h^{0,5} |
| 3) Adhesion to substrate PN-EN 1542:2000 | 1,0 MPa |
| 4) Thermal stability PN-EN 13678-3:2002 | 2,0 MPa |


.....
Verification

Z-ca Kierownika Zakładu
Gipsu i Chemii Budowlanej


mgr inż. Michał Wiczorek

.....
Signature of entitled person